



Service and Maintenance

Regular service and maintenance is critical to keeping your systems running smoothly.

SOFTENER (Iron): Annual cleaning will maintain optimum performance. Clean and lubricate seals, spacers, piston and injector assembly or replace if necessary. Clean brine tank and disinfect. Rebed every 5-7 years.

NEUTRALIZER (pH): Annual cleaning will maintain optimum performance. Clean lubricate seals spacers and piston or replace if necessary. Add calcite media as needed. Rebed every 5-7 years.

GREENSAND (High Iron/Pot Perm Injection): Annual cleaning will maintain optimum performance. Rebed every 7-10 years

PROVECTOR (Oxidizing Iron/Salt free AP tank): Annual cleaning will maintain optimum performance. Rebed every 2-3 years.

ACTIVATED CARBON (odor/booster pump): Annual cleaning yearly to maintain optimum performance.

ASD (Radon Air): Service/inspected every two years to maintain optimum performance.

GAC (Radon Water): Rebed every 18 months.

BUBBLE UP (Radon Water): Service every 2 years to maintain optimum performance.

REVERSE OSMOSIS: Annual service and filters changed yearly will maintain optimum performance.

UV SYSTEM: UV lamp changed yearly.

REBED: Complete replacement of existing media and distributor tube, a detailed process of emptying and re-installing media to the tank and returning system to a productive status.

CARTRIDGE FILTERS: Change every 3-4 months based on usage.